

Classification Report

Number	20-005012-PR02 (NW-C01-05-en-02)
Owner	INOTHERM d.o.o. Prigorica 98 1331 Dolenja vas Slovenia
Product	Single leaf door with side panel RC3
Designation	System: INOTHERM/SCHÜCO Shipping name: EXCLUSIV
Details	Manufacturer INOTHERM d.o.o., - Dolenja vas; Material Aluminium; Attack side Closing face as per EN 12519; Number of case-ments 1 ; Overall dimensions (W x H) 1600 x 2200 ; LSG: Note Class: P5a acc. to EN 356; Lock: Manufacturer KFV Karl Fliether GmbH, & Co. KG - Velbert; Designation AS 2600; Note Class 3 acc. to DIN 18251; Profile cylinder: Manufacturer Aug. Winkhaus GmbH & Co. KG, - Telgte; Designation keyTEC RPE; Note Class 4 (digit 7) and class 1 (digit 8) acc. to EN 1303; Safety shield: Manufacturer ROSTEX VYŠKOV,s.r.o., - Vyškov; Designation Sicherheitsgarnitur ROSTEX RX1; Note Class 3 (digit 7) acc. to EN 1906; Hinge: Manufacturer SCHÜCO International KG, - Bielefeld; Designation Typ 7; Number 3 ; hinge side security 3

Special features

Result

Burglary resistance according to EN 1627:2011-05




Class: RC 3

ift Rosenheim

08.01.2021



Simon Stürer
Deputy Head of Testing Department
Security/Safety Testing



Florian Willer, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Basis *)

Test report: 20-005012-PR02 PB-C01-05-de-02 dated 2.12.2020

Replaced ift-Nachweis No.
20-005012-PR02 (NW-C01-05-en-01) dated 02.12.2020

Representation



Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 4C3-3C6B7